

IEC**IECEE**

®

™

Ref. Certif. No.

CN45989-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Control Relays

Name and address of the applicant

Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Note: When more than one factory, please report on page 2

SCHNEIDER ELECTRIC INDIA PVT LTD
SY NO 99/1, MAMIDIPALLY, Mamidipalle, Balapur, Rangareddy -
500108

Ratings and principal characteristics

Ui:690V;Uimp:6kV;Ith:10A;AC-15: Ue/Ie: 220V/2.1A, 380V/1.3A,
660V/0.75A;DC-13: Ue/Ie: DC220V/0.3A; Us:
AC24V/36V/48V/110V/220V/240V/380V/415V/440V
50Hz,AC24V/110V/220V/380V/440V
60Hz,AC24V/48V/110V/220V/230V/380V 50/60Hz; IP20(from
front face only)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CAE22...,CAE31...,CAE40...;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN45989, dated 2019-02-14. The M1 certificate has been issued to change suppliers of critical parts.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition);IEC 60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-082582-M1

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Sep.25,2024

Signature:

谢肇煦

Xie ZhaoXu