



Ref. Certif. No.

CN45989

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Control Relays
Name and address of the applicant	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Name and address of the manufacturer	Schneider Electric Industries SAS 31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France
Name and address of the factory	SCHNEIDER ELECTRIC INDIA Pvt. Ltd Survey No.215, Village – Gagillapur Medak Road, Rangareddy District, Hyderabad – 500 043, (A.P.) India
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	CAE22...,CAE31...,CAE40...;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007 (5th Edition) + AMD1:2010 + AMD2:2014;IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2018CQC-082582

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>



Date: Feb.14,2019

Signature:

Lu Mei

**CB 0050687**

CAE22...,CAE31...,CAE40...;

Ui:690V;

Uimp:6kV;

Ith:10A;

AC-15:

Ue/Ie:AC220V/2.1A,AC380V/1.3A,AC660V/0.75A;

DC-13:

Ue/Ie:DC220V/0.3A;

Us: 24V/36V/48V/110V/220V/240V/380V/415V/440V 50Hz,

24V/110V/220V/380V/440V 60Hz,

AC24V/48V/110V/220V/230V/380V 50/60Hz;

IP20

Page 1 of 1

Additional information (if necessary)

Date: Feb.14,2019

Signature: 

Lu Mei