

IEC**IECEE**

®

TM

Ref. Certif. No.

CN47462-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric a. s.
Cizovska 447- 39701 Pisek – Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

GVAN, GZ1AN, GVAD, GVAM

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901- CB2019CQC-087027-M1

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jun.29,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0064620

GVAN, GZ1AN, GVAD, GVAM;

Ui:690V;

GVAN:

Uimp:6kV;

Ith:6A;

AC-15:Ue/Ie:690V/0.6A;

DC-13:Ue/Ie:240V/0.5A;

GZ1AN:

Uimp:6kV;

Ith:6A;

AC-15:Ue/Ie:690V/0.6A;

DC-13:Ue/Ie:240V/0.5A;

GVAD fault signaling contact:

Uimp:4kV;

Ith:2.5A;

AC-14:Ue/Ie:240V/0.3A;

DC-13:Ue/Ie:60V/0.15A;

GVAD instantaneous action contact:

Uimp:6kV;

Ith:6A;

AC-15:Ue/Ie:690V/0.6A;

DC-13:Ue/Ie:240V/0.5A;

GVAM:

Uimp:4kV;

Ith:2.5A;

AC-14:Ue/Ie:240V/0.3A;

DC-13:Ue/Ie:60V/0.15A;

Protection degree:IP20

Page 1 of 1

Additional information (if necessary)

Date: Jun.29,2021

Signature:



Xie ZhaoXu