

IEC**IECEE**

®

™

Ref. Certif. No.

CN47511-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Control Relays

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the factory

*Note: When more than one factory, please report on page 2*Schneider Electric Industries S. A.
ZAC Le Village Le Vaudreuil - 27100 - France Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CAD32, CAD50, CAD32...S207, CAD50...S207,
CAD32...S335, CAD50...S335;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN47511, dated 2019-08-09. The M1 certificate has been issued to increase another factory.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-082581-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.29,2023

Signature:

谢肇煦

Xie ZhaoXu



IEC**TECEE**

®

™

Ref. Certif. No.


CN47511-M1

Name of the factory	Address of the factory
PT. Schneider Electric Manufacturing Batam	Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia
SCHNEIDER ELECTRIC INDIA Pvt. Ltd	Survey No.215, Village – Gagillapur Medak Road, Rangareddy District, Hyderabad – 500 043, (A.P.) India

Additional information (if necessary)

Date: Nov.29,2023

Signature:



Xie ZhaoXu

CAD32, CAD50, CAD32...S207, CAD50...S207, CAD32...S335, CAD50...S335

Ui:690V;

Uimp:6kV;

Ith:10A;

AC-15:Ue/Ie:120V/6A, 690V/1.04A;

DC-13:Ue/Ie:125V/1.1A, 600V/0.2A;

CAD32, CAD50:

Us:

AC12V/21V/24V/32V/36V/42V/48V/60V/100V/110V/115V/120V/127V

/140V/200V/208V/220V/230V/240V/277V/380V/400/415V/440V

/480V/500V/575V/600V/660V/690V, 50/60Hz;

DC5V/12V/20V/24V/32V/36V/48V/60V/72V/96V/100V/110V/125V/155V

/174V/200V/220V/250V/305V/348V/440V/543V/575V/600V;

DC(Low Consumption)5V/12V/20V/24V/36V/48V/60V/72V/96V/110V/220V/250V

CAD32...S207, CAD50...S207:

Us: DC24V/72V/110V

CAD32...S335, CAD50...S335:

Us: AC24V/230V, 50/60Hz

IP20,except ring lug connection versions IP10

Page 1 of 1

Additional information (if necessary)

Date:

Nov.29,2023

Signature:

谢肇煦

Xie ZhaoXu