

IEC**IECEE**

®

TM

Ref. Certif. No.

CN48455-M1/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

AC Contactor

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric a. s.
Cizovska 447 - 39701 Pisek - Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LC1F800;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN48455-M1, dated 2021-12-10.
The A1 certificate has been issued to correct report NO. in the certificate.

IEC 60947-4-1:2018

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-088835-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Apr.11,2022

Date:

谢肇旭

Signature:

Xie ZhaoXu

CB 0064014

LC1F800

Ui: 1000V(LA4EM module:380V);

Uimp:8kV(LA4EM module:6kV);

Ith: 1000A;

AC-3: Ue/Ie: AC230V/747.8A, 400V/770.6A, 415V/742.7A, 440V/800A, 500V/616.5A, 690V/469.8A, 1000V/308.2A;

AC-1: Ue/Ie: AC230V/400V/415V/440V/500V/690V/1000V/1000A;

Us: DC110-120V/AC110-120V(40-400Hz),

DC220-240V/AC220-240V(40-400Hz),

DC380-400V/AC380-400V(40-400Hz),

DC100-380V/AC100-250V 50-60Hz;

3P

Model Explanation:

<u>LC1</u>	<u>F800</u>	<u>MW</u>
I	II	III

I	Product type : LC1 : Single contactor
II	Size : F800
III	Coil Voltage Code : FW: DC110-120V, AC110-120V (40-400Hz) MW: DC220-240V, AC220-240V (40-400Hz)

Page 1 of 2

Additional information (if necessary)

Date: Apr.11,2022

Signature:

谢肇煦

Xie ZhaoXu

QW: DC380-400V, AC380-400V (40-400Hz)

KUE: 100-250V ac 50-60Hz / 100-380V dc

Blank : No coil provided, any of the a.m. coil is intended to be assembled by the end user.

Note: FW、MW、QW coils are in fact “dc designed coils”, equipped with an integrated diode bridge which is packaged in coil sub-assembly that will allows them to be used also with ac supply

Note: LC1F800KUE is LC1F800 contactor (no coil version) associated with LXEFW250 coil & LA4EM250FW electronic voltage adapter

Page 2 of 2

Additional information (if necessary)

Date:

Apr.11,2022

Signature:

Xie ZhaoXu