



Ref. Certif. No.

CN50258

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Control relay

Name and address of the applicant

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, Hubei Province, P.R.China

Name and address of the manufacturer

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, Hubei Province, P.R.China

Name and address of the factory

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:690V;Uimp:6kV;Ue/Ie:
AC-15:220V/2.1A,380V/1.3A,600V/0.75A;DC-13:220V/0.3A;Ith:10A
;IP20

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CAE22...N; CAE31...N; CAE40...N;CAN22...N; CAN31...N;
CAN40...N; CAE22...; CAE31...; CAE40...;

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2020CQC-090873

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>



Date:

May.21,2020

Signature:

Lu Mei

CB 0057729