

IEC**IECEE**

®

™

Ref. Certif. No.

CN52978-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

PT. Schneider Electric Manufacturing Batam
JI Beringin Lot4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A
BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk –
Batam, Indonesia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 690V;Ith: 10A; Ue/Ie: AC-15: 120V/6A,
690V/1.04A; DC-13: 125V/0.55A, 600V/0.1A;IP20

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LA1KN;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN52978-M1, dated
2022-01-27. The M2 modification is to add product type with
M.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2020CQC-095389-M2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Apr.18,2023

Signature:

Xie ZhaoXu

CB 0071781