



Ref. Certif. No.

FR\_709764

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

**Switching element**

Tesy's Auxiliary Contact Blocks

Name and address of the applicant

**SCHNEIDER ELECTRIC INDUSTRIES SAS**35, rue Joseph Monier  
92500 RUEIL MALMAISON- FRANCE

Name and address of the manufacturer

**SCHNEIDER ELECTRIC INDUSTRIES SAS**35, rue Joseph Monier  
92500 RUEIL MALMAISON - FRANCE

Name and address of the factory

**SCHNEIDER ELECTRIC A.S.**Cizovska 447  
39701 PISEK - CZECH REPUBLIC

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

Ith: 10A  
Ui: 690V  
Uimp: 6kV  
Type of contact elements: X, Y  
Utilization categories: AC-15, DC-13  
AC-15: Ue=120V/Ie=6A Ue=440V/Ie=1,64A  
DC-13: Ue=125V/Ie=0,55A Ue=600V/Ie=0,1A

Number of contacts: 1NC+1NO, 2NC, 2NO

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

LA1SK11, LA1SK02, LA1SK20

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 697047/A1 dated 03/01/2017. Update further to the evolution of the standard(s), update the manufacturer's address

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 +A1:2010 +A2:2014  
IEC 60947-5-1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

2011990027

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSESSignature:   
Julien Gauthier  
Certification Officer

Date: 25/11/2020