

IEC**IECEE**

Ref. Certif. No.

FR_713464/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker
Motor circuit-breaker

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL-MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL-MALMAISON - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

TeSys GV4L, TeSys GV4LE,
TeSys GV4P, TeSys GV4PE,
TeSys GV4PEM with: Breaking capacity type B, N or S
Terminal EL2 connector or Crimp lug

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_713464 dated 21/03/2022.
Change of the design Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016 +A1:2019
IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

2111996011
2111996011A
2111996011-M1
2111996011A-M1

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien GAUTHIER
Certification Officer

Date: 19/10/2023

ANNEX

Name and address of the factories:

SCHNEIDER (BEIJING)LOW VOLTAGE Co., Ltd
 No 2, Liang Shui He 2nd Street, beijing Economic Technological Development area
 100176 BEIJING - CHINA

SCHNEIDER ELECTRIC INDUSTRIES POLSKA Sp z.o.o.
 ul. MOSTOWA 19 32-332 BUKOWNO - POLAND

References, ratings and main characteristics:

Utilization category	A			
Interruption medium	Air			
Design	Moulded case			
Method of controlling the operating mechanism	Independent manual			
Suitability for isolation	Suitable			
Provision for maintenance	Non-maintainable			
Method of installation	Fixed			
Protection degree :	IP20			
Rated operational voltage U_e : (V)	AC220/240V, 380/415V, 440V, 500V, 525V, 660/690V			
Rated insulation voltage U_i : (V)	800V			
Rated impulse withstand voltage U_{imp} : (kV)	8kV			
Rated current I_n : (A)	2A, 3,5A, 7A, 12,5A, 25A,50A,80A, 115A			
Conventional free air thermal current I_{th} : (A)	Equal to I_n			
Conventional enclosed thermal current I_{the} : (A)	N/A			
Rated current for four pole circuit-breakers : (A)	N/A			
Rated frequency : (Hz)	50/60Hz			
Nature of supply :	AC			
Total number of poles :	3P			
Number of protected poles :	3P			
Rated duty	uninterrupted duty			
Rated short-time making capacity I_{cm} : (A)	N/A			
Rated ultimate short-circuit breaking capacity I_{cu} : (A)		B type	N type	S type
	220/240V	50kA	100kA	120kA
	380/415V	25kA	50kA	100kA
	440V	20kA	50kA	70kA
	500V	10kA	25kA	30kA
	525V	-	15kA	18kA
	660/690V	-	8kA	10kA
Rated service short-circuit breaking capacity I_{cs} : (A)		B type	N type	S type
	220/240V	50kA	100kA	120kA
	380/415V	25kA	50kA	100kA
	440V	20kA	50kA	70kA
	500V	10kA	25kA	30kA
	525V	-	15kA	18kA
	660/690V	-	2kA	2,5kA
Rated short-time withstand current I_{cw} : (A)	N/A			
Electromagnetic compatibility	A			



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 19/10/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 488 363 171
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer

ANNEX

<i>Instantaneous tripping current :</i>	<u>Electronic type (GV4P, GV4PE, GV4PEM)</u> Instantaneous tripping(Ii): 17In for In=2A, 7A, 25A, 50A, 80A, 115A 60A for In=3,5A 213A for In=12,5A <u>Magnetic type(GV4L, GV4LE)</u> Instantaneous tripping(Ii): 6-14In
<i>Reference ambient calibration air temperature : (°C)</i>	N/A
<i>Pollution degree</i>	3
<i>Material group :</i>	IIIa
<i>safety distance (short-circuit tests) :</i>	Up/down: 30/5mm Left/right: 0mm Front/back: 0mm
<i>Shunt release :</i>	MX : 24V 50/60Hz, 48V 50/60Hz, 110-130V 50/60Hz, 220-240V/50Hz/ 208-240V/60Hz, 277V 60Hz, 380-415V 50Hz, 440-480V 60Hz, 24VDC, 48VDC, 125VDC, 250VDC
<i>Undervoltage release:</i>	MN: 24V 50/60Hz, 48V 50/60Hz, 110-130V 50/60Hz, 220-240V/50Hz/ 208-240V/60Hz, 277V 60Hz, 380-415V 50Hz, 440-480V 60Hz, 24VDC, 48VDC, 125VDC, 250VDC
<i>Auxiliary circuits:</i>	OF/SD 1NO1NC AC-15: Ue/Ie: 24V/5A, 48V/5A, 100/127V/4A, 220/240V/3A, 380/440V/2,5A, 660/690V/0,11A DC-13: Ue/Ie: 24V/2,5A, 48V/1,2A, 110V/0,35A, 250V/0,05A

AC-1, AC3 performance for all products:

In	AC-1	AC-3	
	Ith= In	Ie at 415V	Ie at 690V
2A	2A	2A	2A
3,5A	3,5A	3,5A	3,5A
7A	7A	7A	7A
12,5A	12,5A	12,5A	12,5A
25A	25A	25A	25A
50A	50A	50A	50A
80A	80A	80A	80A
115A	115A	100A	80A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 19/10/2023



Signature: **Julien GAUTHIER**
 Certification Officer