



Ref. Certif. No.

HU-002656

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

AC Contactor for capacitive applications

Name and address of the applicant

Schneider Electric SE  
35, rue Joseph Monier, 92500 Rueil Malmaison  
France

Name and address of the manufacturer

Schneider Electric Industries SAS  
31 rue Pierre Mendès France, Eybens 38320  
France

Name and address of the factory

Schneider Electric Industries S.A.  
ZAC Le Village Le Vaudreuil - 27100  
France*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Operating power AC6b: 50, 41,9, 67, 56,1kVAr(690V);  
Ue: 230V, 400-415V, 440V, 550V, 690V; 50/60Hz  
Degree of protection: IP20  
(For details see test report)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

LC1DPK, LC1DTK  
(For details see test report)

Additional information (if necessary may also be reported on page 2)

---

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

28250171 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com

Date: 2019-07-15

Signature:

Erekné Schmidt

