

HU-003699-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

AC Contactor

Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France

Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France

Schneider Electric Industries S. A. ZAC Le Village 27100 Le Vaudreuil, France

Ui:690V; Uimp:6kV; Ith:40...50A; Utilization category: AC-3, AC-4, AC-3e; Ue:AC230...690V; Ie:14,2...38A; with electronic coils (See appendix of CB Test Certificate for further ratings)

Schneider Electric

N/A

LC1D25 , LC2D25 , LC1D32 , LC2D32 , LC1D38 , LC2D38

This Certificate is Modification No.1 to CBTC ref. No. HU-003699, dated 2021-11-26, and is issued due to adding parameter.

IEC 60947-4-1:2018 IEC 60947-5-1:2016

CN21T9OU 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division H-1143 Budapest, Gizella út 51-57., Hungary Web:www.tuv.com

Joseph Land

Date:

2022-05-27

Signature:

Wencai Zhang



HU-003699-M1

Appendix to CB Test Certificate, page 1/1

Type designation:

 $\begin{array}{ccc} \underline{LC1} & \underline{D25} & \underline{6} & \underline{KUE} \\ \hline (1) & (2) & (3) & (4) \end{array}$

Possible values:

(1): Basic product type: LC1: single contactor LC2: reversing contactor

(2): Size:

D25

D32

D38

(3): Type of connection:

Blank: Screw connection

6: Ring lug connection

(4): Coil codes: see below table

Coil code tables:

Coil code	Us(V)	Frequency		
BNE	24-60	50/60Hz and dc		
EHE	48-130	50/60Hz and dc		
KUE	100-250	50/60Hz and dc		

Ratings:

tutings.							
Model	Ith	Utilization	Ue				
		category	230V	400V	440V	500V	690V
LC1D25, LC2D25 40A		Ie(AC-3)	20A	22A	25A	23A	17A
	Ie(AC-4)	16,7A	18,34A	20,84A	19,2A	14,2A	
		Ie(AC-3e)	20A	22A	25A	23A	17A
LC1D32, LC2D32 50A		Ie(AC-3)	27A	29A	32A	28A	21A
	50A	Ie(AC-4)	22,5A	24,2A	20,84	19,2	14,2
	Ie(AC-3e)	27A	29A	32A	28A	21A	
LC1D38, LC2D38 50A		Ie(AC-3)	31,7A	35A	38A	28A	21A
	50A	Ie(AC-4)	26,42A	29,2A	20,84	19,2	14,2
		Ie(AC-3e)	31.7A	35A	38A	28A	21A

Additional information (if necessary)

Date: 2022-05-27

Abnau Zhag Signature: Wencai Zhang