

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Star Delta Starter

Name and address of the applicant

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
France

Name and address of the factory

Note: When more than one factory, please report on page 2

Schneider Electric Industries S. A.
ZAC Le Village
27100 Le Vaudreuil
France

Ratings and principal characteristics

Ui: 1000V; Uimp:8kV; Utilization category: AC-3; 3P;
Ue: AC230V,AC400V,AC440V; In: 177,27A to 232,85A

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LC3D115, LC3D150

Additional information (if necessary may also be reported on page 2)

See additional page(s) for further Additional information.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CN234M05 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-08-22

Signature:



Wencai Zhang

Additional information :

Type designation:

LC3D	115	P7	A64
(1)	(2)	(3)	(4)

Possible values:

- (1): Basic product type LC3D: TeSys Deca Star delta starter
- (2): Size: 115 or 150
- (3): Coil code: see below
- (4): Blank: different contactor category for KM1,KM2,KM3
A64: same contactor category for KM1,KM2,KM3

Coil code	Us (V)	Frequency
Z7	20	50 / 60Hz
B7	24	50 / 60Hz
D7	42	50 / 60Hz
E7	48	50 / 60Hz
K7	100	50 / 60Hz
F7	110	50 / 60Hz
FE7	115	50 / 60Hz
G7	120	50 / 60Hz
L7	200	50 / 60Hz
LE7	208	50 / 60Hz
M7	220-230	50Hz or
	220-240	60Hz
P7	230	50 / 60Hz
U7	230-240	50Hz or
	240	60Hz
Q7	380-400	50 / 60Hz
V7	400	50 / 60Hz
N7	415	50 / 60Hz
R7	440	50 / 60Hz

Electrical data:

Model	Ith	Utilization category	230V	400V	440V
LC3D115	195A	Ie (AC-3)	193,23A	195A	177,27A
LC3D150	232,85A	Ie (AC-3)	229,57A	230A	232,85A



Date: 2023-08-22

Signature:



Wencai Zhang