


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	switch-disconnectors
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier, 92500 Rueil-Malmaison France
Name and address of the manufacturer	Schneider Electric Industries SAS 31, rue Pierre Mendes, 38320 Eybens France
Name and address of the factory	Schneider Electric A.S. Cizovska 447, 397 01 Pisek Czech Republic
<i>When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: AC-21A / AC-22A: Ue 230 V – 690 V, Ie 12 A, 20 A AC-23A: Ue 230 V– 690 V, Ie 8,1 A – 12,3 A AC-3: Ue 230 V– 690 V, Ie 6,3 A – 11,3 A Ui 690 V, Icm 0,5 kA; VN12: Icw 144 A-1s; VN20: Icw 240 A-1s
Trademark / Brand (if any)	SCHNEIDER ELECTRIC
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	VN12, VN20, VZN11, VZN12, VZN14 and VZN20
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with As shown in the Test Report Ref. No. which forms part of this Certificate	IEC 60947-1:2020 and IEC 60947-3:2020 2271000.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 5 November 2023

Signature: Miranda Zhou

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
 (IECEE) CB SCHEME

Additional information

VN12, VN20	3-pole switch-disconnectors
VZN12, VZN20	Main pole modules
VZN11	Neutral pole module
VZN14	Earthing module

Complete units:

VCDN12, VCDN20, VCCDN12, VCCDN2, VBDN12, VBDN20


Model and specifications		VN12 VZN12	VN20 VZN20
Utilization category	Ue (V)	Ie (A)	Ie (A)
AC-21A/AC-22A	230 – 690	12	20
AC-23A	230	10,6	14
	400 / 415	8,1	11,5
	500	8,9	11,9
	690	8,6	12,3
AC-3	230	6,3	11,3
	400 / 415	6,5	8,5
	500	6,8	9,9
	690	6,7	8,9

Models and specification

VZN11	Neutral pole module 230 – 690 V 20 A
VZN14	Protective earth module 230 – 690 V 20 A

This CB Test Certificate is issued by the National Certification Body

 DEKRA Certification B.V.
 Meander 1051
 6825 MJ Arnhem
 Netherlands




Date: 5 November 2023

Signature: Miranda Zhou