

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
 CERTIFICATES FOR ELECTRICAL EQUIPMENT
 (IECEE) CB SCHEME

 SYSTEME CEI D'ACCEPTATION MUTUELLE DE
 CERTIFICATS D'ESSAIS DES EQUIPEMENTS
 ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

 Product
 Produit

 Accessory for Uninterruptible Power Supply (UPS)
 Service Bypass Panel

 Name and address of the applicant
 Nom et adresse du demandeur

 APC by Schneider Electric
 85 Rangeway Road Building #2, NORTH BILLERICA MA 01862
 UNITED STATES OF AMERICA

 Name and address of the manufacturer
 Nom et adresse du fabricant

 APC by Schneider Electric
 85 Rangeway Road Building #2, NORTH BILLERICA MA 01862
 UNITED STATES OF AMERICA

 Name and address of the factory
 Nom et adresse de l'usine

 Schneider Electric (I) Pvt Ltd
 Plat No. 24B, Phase 1, Jigani
 Industrial Area, Jigani Hobli,
 Anekal Taluk
 562106 Bangalore

 Note: When more than one factory, please report on page 2
 Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

 Additional Information on page 2

 Ratings and principal characteristics
 Valeurs nominales et caractéristiques principales

 Input: AC 230 V, 50 / 60 Hz, max. 10 or16A
 Output: AC 230 V, 50 / 60 Hz, max. 10 or16A

 Trademark (if any)
 Marque de fabrique (si elle existe)

APC

 Type of Manufacturer's Testing Laboratories used
 Type de programme du laboratoire d'essais constructeur

TMP

 Model / Type Ref.
 Ref. De type

SBP1500RMI, SBP3000RMI, SBP3000RMHW

 Additional information (if necessary may also be
 reported on page 2)

Ambient max. 40°C

 Les informations complémentaires (si nécessaire,
 peuvent être indiqués sur la 2^{ème} page)

 Additional Information on page 2

 A sample of the product was tested and found
 to be in conformity with
 Un échantillon de ce produit a été essayé et a été
 considéré conforme à la

IEC 62040-1(ed.1)

 As shown in the Test Report Ref. No. which forms part
 of this Certificate

1924400-3335-0061/192370

 Comme indiqué dans le Rapport d'essais numéro de
 référence qui constitue partie de ce Certificat

 This CB Test Certificate is issued by the National Certification Body
 Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**
VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
 Zertifizierungsstelle / Certification



E. Biehl

Date: 2014-05-07

Signature:



Ref. Certif. No.

DE1-53820

Schneider Electric (I) Private Ltd.
Plant IDF 1 & IDF 2, 187/3, 188Jigani Village
Jigani Hobli
562106 BANGALORE
INDIA

Additional information (if necessary)
Information complémentaire (si nécessaire)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

Date: 2014-05-07

Signature:

E. Biehl