

IEC**IECEE**

®

™

Ref. Certif. No.

CN54412-A1/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

AC Contactor

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

*Note: When more than one factory, please report on page 2*Schneider (Shanghai) Apparatus Parts Manufacturing Co., Ltd.
Putuo Branch
Block A, Building 2, No.629 Suid Road, Putuo District,
Shanghai

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LC1F1400, LC1F1700, LC1F2100;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN54412-A1, dated 2022-02-16. The M1 modification is to change suppliers of critical parts.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-096235-A1/M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.11,2023

Signature:

谢肇煦

Xie ZhaoXu



LC1F1400, LC1F1700, LC1F2100

Uimp: 8kV; Ui: 1000V;

LC1F1400 (2 busbars per pole):

Ith: 1400A ;

AC-1: Ue/Ie: 1000V/1400A;

LC1F1700 (3 busbars per pole):

Ith: 1700A ;

AC-1: Ue/Ie: 1000V/1700A;

LC1F2100+LA9F2100 adapter (3 busbars per pole):

Ith: 2000A ;

AC-1: Ue/Ie: 1000V/2000A;

LC1F2100+LA9F2100 adapter (4 busbars per pole):

Ith: 2100A ;

AC-1: Ue/Ie: 1000V/2100A;

Us: AC110V, 120V, 220V, 230V, 240V, 277V, 380V, 400V, 415V, 440V, 500V, 40-400Hz;

DC110V, 125V, 200V, 220V, 250V, 440V;


Poles: 3P

Additional information (if necessary)

Date:

Sep.11,2023

Signature:



Xie ZhaoXu