



Ref. Certif. No.

CN50979

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic overload relay
Name and address of the applicant	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France
Name and address of the manufacturer	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France
Name and address of the factory	Schneider Electric France 6-8, rue du Bailly - BP 97812 - 21078 Dijon Cedex - France
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	LR9F7.75, LR9F75, LR9F7.79, LR9F79, LR9F7.81, LR9F81;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2020CQC-090963


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn



Date: Aug.10,2020

Signature: 
Lu Mei

LR9F7.75, LR9F75, LR9F7.79, LR9F79, LR9F7.81, LR9F81;

Ui:1000V;

Uimp:8kV;

LR9F7.75, LR9F75: Ue:690V,Ie: 200-330A;

LR9F7.79, LR9F79: Ue:690V,Ie: 300-500A;

LR9F7.81, LR9F81: Ue:500V,Ie: 380-630A;

Trip class:

LR9F7375, LR9F7379, LR9F7381:10;

LR9F7575, LR9F7579, LR9F7581:20;

LR9F75, LR9F79, LR9F81:10,20;

Number of poles:3P;

Auxiliary contacts: (body contact)

Ith:5A;

AC-15:Ue/Ie:24V/4.16A,220V/2.72A, 600V/1A;

DC-13:Ue/Ie: 24V/4.16A,220V/0.2A, 440V/0.05A;

1NO1NC

Page 1 of 1

Additional information (if necessary)

Date:

Aug.10,2020

Signature:



Lu Mei