

Ref. Certif. No.  
**SE-87253**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**


**CB TEST CERTIFICATE**

Product	Residual current operated circuit-breaker with integral overcurrent protection for household and similar uses (RCBO's)
Name and address of the applicant	Schneider Electric Industries SAS 31, rue Pierre Mendès, F-38050 Grenoble Cedex 9, FRANCE
Name and address of the manufacturer	Same as factory
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Schneider Electric Thailand Ltd. 540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road, Muang District, Samutprakarn 10280, THAILAND
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	iC60H, iC60N
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	170300045SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00  
  
Date: 9 June 2017



Signature:   
Bo Berglöf

**Additional information (if necessary)**

Ratings and principal characteristics

Model	Ue(V)	Icn(A)	IΔn(mA)	Type	Poles	In(A) and Type
iC60H	110/130V	10000	30	A	1P+N	C10, C16, C20, C25, C32
iC60N	240V	6000	30	A	1P+N	C6, C10, C16, C20, C25, C32, C40, C45
iC60H	240V	10000	30	A	1P+N	B6, B10, B16, B20, B25, B32, B40, B45
iC60H	240V	10000	10, 30, 100	A	1P+N	C6, C10, C16, C20, C25, C32, C40, C45

Covered also BS EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12: 2016 and AS/NZS 61009.1:2015

This certificate replaces SE-70682M1, dated 5 May 2015. A new certificate has been issued due to updated standard.

Date: 9 June 2017

Signature: 