



Ref. Certif. No.

DK-83997-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

EMERGENCY STOP DEVICE (PUSH BUTTON SWITCH) : Harmony range XB4 metal and XB5 plastic.

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35 RUE JOSEPH MONIER
RUEIL MALMAISON 92500 FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35 RUE JOSEPH MONIER
RUEIL MALMAISON 92500 FRANCE

Name and address of the factory

SCHNEIDER ELECTRIC / DBA TELEMECANIQUE
ZONE INDUSTRIELLE
BP660 L'ISLE D'ESPAGNAC 16340 FRANCE

Note: When more than one factory, please report on page 2

[Additional Information on page 2](#)

Ratings and principal characteristics

Utilization category : AC15 - DC13
A600 - Q600 - A300 - Q300 - R300 - P300 - B300

[Additional Information on page 2](#)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Series XB4, XB5, ZB4, or ZB5 followed by BS83, BS84, BS86, BS93, BS94, BS96, BT84, BX84, AS83, AS84, AS86, AS93, AS94, AS96, AT84, AT86, AX84 followed by additional suffixes, and fitted with : ZB..Z009 + ZBE, ZEN or ZB2 followed by additional digits XALK84, XALK178 followed additional suffixes.

[Additional Information on page 2](#)

Additional information (if necessary may also be reported on page 2)

The report was revised to include technical modifications.

[Additional Information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007, IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014, IEC 60947-5-1:2016, IEC 60947-5-5:1997, IEC 60947-5-5:1997/AMD1:2005, IEC 60947-5-5:1997/AMD2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

4789683500B issued on 2021-11-22

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-11-29
Original Issue Date: 2019-05-28

Signature: Jan-Erik Storgaard



Ref. Certif. No.

DK-83997-M1-UL

Factory(ies):

SCHNEIDER ELECTRIC A.S.
CIZOVSKA 447 PISEK 397 01
CZECH REPUBLIC

PT. SCHNEIDER ELECTRIC MANUFACTURING BATAM
BATAMINDO INDUSTRIAL PARK
JL BERINGIN LOT 1, 4 & 208
MUKA KUNING BATAM 29433 INDONESIA

Additional Ratings:

Resistive
Protection degree :
66 (front, all)
67 (front, only for ZB5AS84W, XALK84W, XALK178W series)
20 (back, all)
See CB test report for complete detailed ratings.

Additionally evaluated to:

EN 60947-1:2007, EN 60947-1:2007/A1:2011, EN 60947-1:2007/A2:2014, EN 60947-5-1:2017

Summary of Modifications:

Add contact monitoring and adaptator - see CB Test Report for details.

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-11-29
Original Issue Date: 2019-05-28

Signature:

Jan-Erik Storgaard