

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN51450

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Auxiliary Contacts

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

InnoVista Sensors Industry (Huizhou) Ltd.
3rd and 4th Floor, No.6 Huifeng West 2nd Road, Pingnan Industrial Park, Zhongkai Hi-tech Industrial Development Zone, Huizhou, Guangdong Province, P.R.China

See the Appendix

Schneider Electric

29450, 29452

IEC 60947-5-1:2016(4th Edition)

00901-CB2019CQC-086554

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Oct.14,2020

Signature:

陆梅

Lu Mei



CB 0058094

29450,29452

Ui:690V(29450),480V(29452);

Uimp:8kV;

Ith:6A(29450),5A(29452)

Ue/Ie:

29450:

AC-12: AC24V/48V/110V/220/240V/380/440V/480V/660/690V/6A;

AC-15:AC24V/48V/6A,110V/5A,220/240V/4A,380/440V/2A,480V/1.5A,660/690V/0.1A;

DC-12:DC24V/6A, 48V/2.5A,110V/0.6A,250V/0.3A;

29452:

AC-12:AC24V/48V/110V/220/240V/250V/380/440V/480V/5A;

AC-15:AC24V/48V/3A,110V/2.5A,220/240V/2A,380/440V/1.5A,480V/1A;

DC-12:DC24V/5A,48V/2.5A,110V/0.6A,250V/0.3A;

Page 1 of 1

Additional information (if necessary)

Date: Oct.14,2020

Signature:



Lu Mei