

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Arc fault detection device (AFDD)

Name and address of the applicant

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France,  
38050 Grenoble Cedex 9, France

Name and address of the manufacturer

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France,  
38050 Grenoble Cedex 9, France

Name and address of the factory

Schneider Shanghai Low Voltage Terminal Apparatus Co. Ltd.  
1319 PingAn Road,  
201109 Shanghai, China

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

In = 25 A; Un = AC 230/240 V; Inc = 10 kA

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

iARC Generic Ref.: AFDS0S225  
Commercial Ref.: A9TS1225

Additional information (if necessary may also be reported on page 2)

AFDD according to Clause 4.1.1 of IEC 62606. See also general product information on page 12 of test report CTI-CB 1019-1.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62606:2013  
IEC 62606:2013/AMD1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1019-1, CTI-CB 1022-3.

This CB Test Certificate is issued by the National Certification Body

Österreichischer Verband für Elektrotechnik  
Testing and Certification  
Kahlenberger Str. 2A, 1190 Wien, Austria

Date: 2020-02-11

Digitally signed by W. Martin  
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin