



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305659853

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND LOCATION OF THE FACTORY

AIH – E. A. DU PHENIX
4 Rue Nicolas Appert 41700 Contres - France

PRODUCT NAME,MODEL AND SPECIFICATION

Pendant Control Station
XAC A, PBX P : Ui:600V ; Uimp:6kV ; Ith:10A ; AC-15:Ue/Ie:240V/3A ; DC-13:Ue/Ie:250V/0.27A ;
IP65

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.18,2024

Valid until: Jul.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305659853

Appendix: Page 1 of 2

型号解释:

<u>XAC-A</u> <u>PBXP</u> I	<u>21</u> <u>B</u> II	<u>7</u> <u>Y</u> III	<u>3</u> <u>01</u> IV
I	XAC-A 系列控制盒		PBXP 系列控制盒
II	按钮类型 20: 标准型 21: 带罩的		按钮类型 A: 标准型 B: 带罩的
III	按钮所对应的触头类型和数量 1:1NO (ZB2-BE101) 2:1NO(ZB2-BE101)+1NO(ZB2-BE101) 5:1NO(ZB2-BE101)+1NC(ZB2-BE102) 7:1NO(ZB2-BE101)+1NO(先 闭 合 ZB2-BE201)		按钮所对应的触头类型和数量 R: 1NO (ZB2-BE101) S: 1NO(ZB2-BE101) + 1NO(ZB2-BE101) T: 1NO(ZB2-BE101) + 1NC(ZB2-BE102) Y: 1NO(ZB2-BE101) + 1NO(先 闭 合 ZB2-BE201)
IV	急停按钮类型 空白: 没有急停按钮 3:标准操动头(ZB5-AS834) 4:触发动作的急停按钮(操作头 ZB5-AS834+触头模块 1NC ZB2-BE102)		急停按钮类型 空白: 没有急停按钮 01: 标准操动头(ZB5-AS834) 02: 触发动作的急停按钮(操作头 ZB5-AS834 + 触头模块 1NC ZB2-BE102)

注: XAC-A 和 PBXP 的差异仅仅在于前盖和后盖的颜色。产品结构和所有使用的原材料材质及所有技术参数完全等同。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305659853

Appendix: Page 2 of 2

<u>XAC A</u> <u>PBX P</u> I	<u>21</u> <u>B</u> II	<u>7</u> <u>Y</u> III	<u>3</u> <u>01</u> IV
I	XAC-A series Pendant Control Stations		PBXP series Pendant Control Stations
II	Type of push-button 20 : Standard 21: Booted		Type of push-button A : Standard B: Booted
III	Type and number of contacts under push-button 1 : 1NO (ZB2-BE101) 2: 1NO(ZB2-BE101)+1NO(ZB2-BE101) 5: 1NO(ZB2-BE101)+1NC(ZB2-BE102) 7: 1NO(ZB2-BE101) + 1NO(early make ZB2-BE201)		Type and number of contacts under push-button R : 1NO (ZB2-BE101) S : 1NO(ZB2-BE101) + 1NO(ZB2-BE101) T : 1NO(ZB2-BE101) + 1NC(ZB2-BE102) Y: 1NO(ZB2-BE101)+1NO(early make ZB2-BE201)
IV	Type of emergency switch Blank: Without emergency switch 3:Standard operating head (ZB5-AS834) 4:Trigger action operating head (type : ZB5-AS834 + contact 1NC ZB2-BE102)		Type of emergency switch Blank: Without emergency switch 01: Standard operating head (ZB5-AS834) 02: Trigger action operating head (type : ZB5-AS834 + contact 1NC ZB2-BE102)

Note: the difference between XAC A and PBX P is the colour of back cover and front cover only. The product structures & all the used raw material types and all technical data are same.

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.