



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305659698

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND LOCATION OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

PRODUCT NAME,MODEL AND SPECIFICATION

Emergency Stop Switch
XB7N : Ui:250V;Uimp:6kV;AC-15:Ue/Ie:AC240V/1.5A , AC120V/3A;Ith:5A;IP65 (before installing
the panel) , IP20 (After installing the panel) ; Mounting apertureΦ : 22.0mm

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.18,2024

Valid until: Jul.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305659698

Appendix: Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

型号解释:

1. 急停开关（旋转复位）Emergency Stop Switch (Twist to Release)

.XB7 NS .8. .4. .4. .2.
I II III IV V

I - 产品系列号及基本功能 Designate the series and the function

XB7 NS: 旋转复位 Twist to Release

II - 操作头描述 Description of Head

8- 旋转复位 Turn to Release trigger action

9- 钥匙复位 Key Release trigger action

III - 操作头直径 Diameter of the head

4 - 40mm

IV - 操作头颜色 Color of the Head

4 - 红色 Red

V - 触头类型 Contacts

2 - N/C

4 - N/C + N/C

5 - N/C + N/O

2. 急停开关（拉拔复位）Emergency Stop Switch (Pull to Release)

.XB7 NT .8. .4. .2.
I II III IV

I - 产品系列号及基本功能 Designate the series and the function

XB7 NT: 拉拔复位 Pull to Release

II - 操作头描述 Description of Head

8- 拉拔复位/操作头直径 40mm Push Pull trigger action 40mm diameter

III - 操作头颜色 Color of the Head

4 - 红色 Red

IV - 触头类型 Contacts

2 - N/C

4 - N/C + N/C

5 - N/C + N/O

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.