



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER Schneider Electric (Australia) Pty. Ltd.

PLACE OF PRODUCTION Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road,
Gepps Cross, SA 5094
AUSTRALIA

Clipsal Manufacturing (M) Sdn Bhd
No.1, Jalan Kawat 15/18, Seksyen 15,
40200 Shah Alam, Selangor Darul Ehsan
MALAYSIA

Schneider Electric New Zealand Limited
11 Moncur Place, Addington,
Christchurch 8024
NEW ZEALAND

DESCRIPTION Enclosures , Boxes and Distribution Boards

TYPE 56E Series
56E1, 56ES1, 56E2, 56ED2, 56ES2, 56EV2, 56EV2/225,
56EV232, 56E3, 56E4, 56E4VH, 56E6, 56E8, 56E9, 56E16,
56E8SB, 56E9SB

56L Series
56L1, 56L1/22, 56L1/22/2, 56L1/30, 56L1/30/2, 56L2,
56L3, 56L4

Certificate No. 14/20074

Issue Date 08 December 2014

Expiry Date 07 December 2019

Sheet 1 of 2

*Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS*

Jörn Brüggemann
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



56CB4 series
56CB4, 56CB4N, 56CB4NM

56JB Series
56JB1, 56JB2, 56JB3, 56JB4, 56JB1SWA

56SB Series
56SB4, 56SB13

56DB Series
56XDB1, 56DB2, 56DB3, 56DB4, 56XDB4, 56DB6, 56XDB6, 56DB9

Adaptable Enclosures
56/32, 56/01/1, 56/01X

RATING degree of protection: IP66 only installed Components form the 56 series

APPLICATION Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV5, as defined in LR Type Approval Test Specification No. 1-2013 where the Test Specification is satisfactory for the intended operation.

STANDARD AS 60529:2004

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. HTS/ETS 30660-14 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 14/20074
Issue Date 08 December 2014
Expiry Date 07 December 2019
Sheet 2 of 2

Jörn Brüggemann
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group