

IEC**IECEE**

Ref. Certif. No.

CN47576-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contacts

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the factory

Satys Electric (Thailand) Company Limited
55/20, 77 Moo 15 Tambon Bangsaothong, Amphur
Bangsaothong, Samutprakarn, 10570 Thailand*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

PF Standard, PF Low Level

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN47576, dated 2019-08-09.
The first modification is to change critical parts.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2016CQC-071819-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.10,2023

Signature:

Xie ZhaoXu

IEC**TECEE**

®

™

Ref. Certif. No.

CN47576-M1

PF Standard, PF Low Level

PF Standard:

Uimp:6kV;

Ui:480V;

Ith:5A;

Ue/Ie:

AC-12:AC240V/5A,380V/5A,480V/2A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A;

PF Low Level:

Uimp:6kV;

Ui:250V;

Ith:3A;

Ue/Ie:

AC-12:AC24V/48V/3A,240V/3A;

DC-12:DC24V/3A,48V/3A,125V/0.3A,250V/0.15A


Page 1 of 1

Additional information (if necessary)

Date:

Nov.10,2023

Signature:



Xie ZhaoXu