



Ref. Certif. No.

CN47577

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

Auxiliary Contacts

Name and address of the applicant

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS  
31 rue Pierre Mendès-France 38320 EYBENS, France

Name and address of the factory

Satys Electric (Thailand) Company Limited  
55/20, 77 Moo 15 Tambon Bangsaothong, Amphur  
Bangsaothong, Samutprakarn, 10570 Thailand

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

OF Standard, OF Low Level

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2016CQC-071863

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

#### CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>



Date: Aug.09,2019

Signature:

Lu Mei

CB 0053637

OF Standard, OF Low Level

OF Standard:

Uimp:8kV;

Ui:690V;

Ith:6A;

Ue/Ie:

AC-12: AC240V/380V/6A,480V/6A,690V/6A;

DC-12:DC24V/2.5A,48V/2.5A,125V/0.5A,250V/0.3A;

PF Low Level:

Uimp:8kV;

Ui:380V;

Ith:5A;

Ue/Ie:

AC-12:AC24V/48V/5A,240V/380V/5A;

DC-12:DC24V/5A,48V/2.5A,125V/0.5A,250V/0.3A

Page 1 of 1

Additional information (if necessary)

Date: Aug.09,2019

Signature: 

Lu Mei