



Ref. Certif. No.

CN50078

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Auxiliary Contact
Name and address of the applicant	Schneider Electric Industries SAS 31 rue Pierre Mendès-France 38320 EYBENS, France
Name and address of the manufacturer	Schneider Electric Industries SAS 31 rue Pierre Mendès-France 38320 EYBENS, France
Name and address of the factory	Auge Micro Technic Tunisia ZONE INDUSTRIELLE N 1 BP 28 9070 MEDJEZ EL BAB TUNISIA
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui: 690V;Uimp: 8kV;AC-12: Ue/Ie: AC240/380V/10A, AC480V/10A, AC690V/6A;DC-12: Ue/Ie: DC24/48V/10A, DC125V/10A, DC250V/3A; Ith: 10A
Trademark (if any)	Schneider electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	4OF;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2018CQC-079828


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn



Date: May.06,2020

Signature: 
Lu Mei

CB 0056080