



Ref. Certif. No.

CN54533

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Thermal Overload Relays
Name and address of the applicant	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Name and address of the manufacturer	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Name and address of the factory	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Uimp:6kV; Ui:690V; Ue:AC690V; Ie:17-25A,23-32A,30-40A,37-50A,48-65A; Tripping class:10A; 3P; IP20(from front face only) Auxiliary contacts: (body contact): Ue/Ie:AC-15:AC120V/3A,AC500V/0.72A,AC600V/0.12A,AC690V/0.09A; DC-13:DC125V/0.22A,DC440V/0.06A
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	LRD3
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2021CQC-097069

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn



Date: Sep.07,2021

Signature: 
Xie ZhaoXu

CB 0064284