



Certificate of Compliance

Certificate: 2155978 **Master Contract:** 225619 (044087_S_000)
Project: 70208718 **Date Issued:** 2019-01-17
Issued to: **Telemecanique/Schneider Electric Industries SAS**
BP 660
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Khalil Ouldchama*
Khalil Ouldchama

PRODUCTS

CLASS - C321103 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices
CLASS - C321183 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers-Auxiliary Devices-Certified to U.S. Standards

Biometric switch, fingerprint reader, open type, Cat. No. XB5 S, followed by 1, 2, 3, 4, 5, 6 or 7 followed by B, followed by 2, followed by L with a number or followed by M12; rated 24 Vdc supply, 200 mA PNP-output, resistive, protected against overload and short-circuit; enclosure Type 12.

Notes:

- 1) These open type devices are certified for use in other certified equipment where the suitability of the combination is determined by CSA.
- 2) Non-evaluated as a biometric operating device where its suitability within the end use application shall require further evaluation should this feature be considered critical for safety.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-18	-	Industrial Control Equipment
CAN/CSA-C22.2 No. 94.2-15	-	Enclosures for electrical equipment, environmental considerations
ANSI/UL 508 (18 th Edition)	-	Industrial Control Equipment
ANSI/UL 50E (2 nd Edition)	-	Enclosures for Electrical Equipment, Environmental Considerations