



27 October 2017

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Attention: Les Blaszczyk

Dear Sir / Madam,

APPROVAL OF NON-PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Office of the Technical Regulator on telephone -, or email tim.rahill@sa.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in blue ink that reads "George Nairn".

AUTHORISED OFFICER

Ref: OTR170528/00



Certificate Number: OTR170528/00



Certificate of Suitability

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

Registered Declarant: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Authorised Marking: OTR170528

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification should be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 1 NP: Non-Prescribed RCBO - (6-32)A, 110V, 30mA for mining
Relevant Standards:	AS/NZS 61009: 2015
Expiry Date:	27 October 2022
Conditions of Approval:	

A handwritten signature in blue ink that reads 'George Neale'.

DATE OF APPROVAL: 27 October 2017 Page: (2/ 4)

Authorised officer



Government of South Australia
Department of State Development

Certificate Number: OTR170528/00



A handwritten signature in blue ink that reads 'George Nasic'.

Authorised officer

DATE OF APPROVAL: 27 October 2017 Page: (3/ 4)



Government of South Australia
Department of State Development

Certificate Number: OTR170528/00



Approval details

Clipsal 4RCBESlim series, iSPN Vigi class RCBOs, 6-32A, 110V, 30mA Curve-C, Type A, 6kA The single-phase iSPN Vigi self-contained residual current device carries out: 1. protection of persons against direct and indirect contacts - 30 mA 2. complete protection of final circuits (overcurrents and insulation faults) 3. safety device to switch both of active and neutral. 4. A class iSPN Vigi are sensitive to the pulsed type DC component. 5. Overload, short circuit and earth fault currents are indicated by location of the handle in the OFF position. 6. A push-test button "T" is positioned on the front of the device for testing that product is operational.

Model	4RCBE206S110, 4RCBE210S110, 4RCBE216S110, 4RCBE220S110, 4RCBE225S110, 4RCBE232S110
Rated at	Input: 110 Vac, 30mA, 6kA, A Type, C-Curve, 6, 10, 16, 20, 25, 32 A
Trade Name	Clipsal
Comments	

