

CERTIFICATE OF SUITABILITY

Authorised marking: TUV022977E

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross, SA 5094, Australia

DESCRIPTION OF EQUIPMENT

Declared class: Non-declared

Product: Switched Socket Outlet and Switched Appliance Inlet.

Trade Name / Manufacturer: Wilco; Clipsal.

Model Number: WCFSP series.
(Further model details refer to CONTINUATION SHEET 1).


Ratings: 500Va.c., 50Hz, 3 Phase, AC-22B.
(Ratings details refer to CONTINUATION SHEET 1).
Remarks: Product: Switched Socket Outlet and Switched Appliance Inlet (For Industrial Application).

Standard: AS/NZS 3123:2005
AS/NZS 3100:2017+A1
AS/NZS IEC 60947.3:2015

Issue Date: 14/09/2018

Expiry Date: 14/09/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd


Billy Chu

CERTIFICATE OF SUITABILITY

Authorised marking: TUV022977E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Description : Model No. / Voltage (V~) / Current (A) /
Number of contacts or pins / IP ratings:

Switched Socket- outlet Designed to accept 63A HRC fuse :
WCFSP563-EC / 500 / 63 / 5 contacts / IP53;

Switched Socket- outlet Designed to accept 100A HRC fuse :
WCFSP4100-EC / 500 / 100 / 4 contacts / IP53;

Switched Socket- outlet Designed to accept 100A HRC fuse :
WCFSP5100-EC / 500 / 100 / 5 contacts / IP53;


Switched Appliance inlet Designed to accept 100A HRC fuse :
WCFSP5100R / 500 / 100 / 5 round pins / IP53.

Remarks: Rating IP53 when engaged with matching plug and
IP43 when is not engaged.

Issue Date: 14/09/2018

Expiry Date: 14/09/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register