



# CB TEST CERTIFICATE

Ref. Certificate No.

BE-2471

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	SGS Belgium NV - Division SGS CEBEC		
Product:	Isolating switches		
Applicant:	Schneider Electric Industries SAS	31, rue Pierre Mendès France, Eybens 38050 GRENOBLE CEDEX 09	France
Manufacturer:	Schneider Electric Industries SAS	31, rue Pierre Mendès France, Eybens 38050 GRENOBLE CEDEX 09	France
Factory:	Schneider Electric NV/SA	Dieweg, 3 1180 BRUSSEL	Belgium
Rating and principal characteristics:	See page 2		
Trade mark (if any):	SCHNEIDER ELECTRIC		
Type of Manufacturer's Testing Laboratories used:	SMT		
Model/Type reference:	Series iSW		
Additional information:	/		
Sample of product tested to be in conformity with IEC:	60669-2-4(ed.1)		
Test Report Ref. No:	58182202/00 and 58182201/00 up to 58182201/07		

This CB Test Certificate is issued by the National Certification Body:

SGS Belgium NV - Division SGS CEBEC  
Riverside Business Park Avenue Internationalelaan 55 Build. D B - 1070  
Brussels, Belgium

Signed by: Calogero LANA

Date of issue: 2010-07-14

SGS



**Ratings:**

pattern no(s).	:	1, 2, 3 & 03
rated voltage (Un)	:	250 Vac (1P) and 415 Vac (2P, 3P & 4P)
rated current (In)	:	20 A & 32 A
method of actuating	:	tumbler
method of application	:	semi flush-type, DIN rail
terminals	:	screw-type

---



Product References:

Base Modules				Ratings	
	Ref	P	Pattern	In (A)	Un (V)
<i>iSW</i>	A9S60120	1	1	20	250
	A9S60220	2	2	20	415
	A9S60320	3	3	20	415
	A9S60420	4	03	20	415
	A9S60132	1	1	32	250
	A9S60232	2	2	32	415
	A9S60332	3	3	32	415
	A9S60432	4	03	32	415
<i>iSW with indicator light</i>	A9S61220	2	2	20	250
	A9S61232	2	2	32	250


 The logo consists of the word "CEBEC" in a bold, sans-serif font, enclosed within a rectangular border that has a slightly irregular, hand-drawn appearance.
 

CEBEC