

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Circuit-breakers for overcurrent protection for household and similar installations

## Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS  
31 rue Pierre Mendès France, Eybens  
F-38050 Grenoble Cedex 9  
France

## Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS  
31 rue Pierre Mendès France, Eybens  
F-38050 Grenoble Cedex 9  
France

## Name and address of the factory

*Note: When more than one factory, please report on page 2*

SCHNEIDER ELECTRIC BULGARIA EOOD  
Plovdiv plant  
4202 Radinovo  
Bulgaria

[Additional information on page 2](#)

## Ratings and principal characteristics

3P or 3P+N; Ue = 400 V; 50-60 Hz; Icn = 3000 A  
Curve C – In = 32 A  
(see also pages 6 and 7 of Test Report No. PB22-0081627-01-02  
and/or Additional Sheet)

## Trademark / Brand (if any)



Schneider Electric

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

Resi9 XE series, generic reference R9E3C60a3C32 or R9E3C60a3PhNC32  
(see also page 6 of Test Report PB22-0081627-01-02 or Additional Sheet)

## Additional information (if necessary may also be reported on page 2)

[Additional information on page 2](#)

## A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

**National differences:**  
EU Group Differences

## As shown in the Test Report Ref. No. which forms part of this Certificate

PB22-0081627-01-02

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.  
Via Quintiliano 43  
Milano, 20138  
Italy



Date: 2022-12-16

Signature: Mauro Casari

**Generic reference of the circuit-breakers for  
overcurrent protection Resi9 XE series and related ratings**

Generic reference	Number of poles	Curve	Rated current
R9E3C60a3C32	3P	C	32 A
R9E3C60a3PhNC32	3P+N		

The circuit-breakers for overcurrent protection Resi9 XE series are suitable to be mounted on the following bases for plug-in connection:

Generic reference	Designation	Suitable for
R9XEDOM3PNP12	Distri 12M	3P+N circuit-breakers
R9XEDOM3PNP18	Distri 18M	
R9XEDOM3PNP24	Distri 24M	
R9XEDOM3PP18	Distri 18M	3P circuit-breakers
R9XEDOM3PP24	Distri 24M	