

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DC Switch-disconnector

Name and address of the applicant

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
France

Name and address of the factory

Merlin Gerin Ales
16 Boulevard Charles Peguy
30100 ALES Cedex
France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui=1000V; Uimp=6kV; Ith=100A;
DC-21B: Ue=1000VDC; Ie=100A;
Icw=1,5kA, 0,5s; Icm=1kA

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

C120NA-DC (A9N61701)

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020
IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

HU22IXC3 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-10-28

Signature:



Tötös Tamás László