


CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS

STR/2652/IMQ

Product	Circuit-breakers for overcurrent protection for household and similar installations
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	SCHNEIDER ELECTRIC BULGARIA EOOD Plovdiv plant – 4202 Radinovo – Bulgaria
Preliminary visit carried out by	—
Rating and principal characteristics	3P or 3P+N; Ue = 400 V; 50-60 Hz; Icn = 3000 A Curve C – In = 6, 10, 16, 20 and 25 A (see also pages 8 and 9 of Test Report No. PB22-0078439-01-00 and/or Additional Sheet)
Trade mark (if any)	
Model/Type Ref.	Resi9 XE series (see also page 9 of Test Report No. PB22-0078439-01-00 or Additional Sheet)
Additional information (if necessary)	—
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
• EN 60898-1:2019	
as shown in the test reports (reference No.)	PB22-0078439-01-00 and from PB22-0078439-01-01 to PB22-0078439-01-05

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.

Milano, 2022-07-13

Signature of the authorized person _____

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731
Fax.: (+39) 02-50991500
e-mail: info@imq.it

20138 MILANO – Via Quintiliano, 43 – ITALY

**STATEMENT OF TEST RESULTS**

Additional Sheet to STR/2652/IMQ

**Generic reference of the circuit-breakers for
overcurrent protection Resi9 XE series and related ratings**

Generic reference	Number of poles	Curve	Rated current
R9E3DOM3C6	3P	C	6 A
R9E3DOM3C10			10 A
R9E3DOM3C16			16 A
R9E3DOM3C20			20 A
R9E3DOM3C25			25 A
R9E3DOM3PhNC6	3P+N		6 A
R9E3DOM3PhNC10			10 A
R9E3DOM3PhNC16			16 A
R9E3DOM3PhNC20			20 A
R9E3DOM3PhNC25			25 A

The circuit-breakers for overcurrent protection Resi9 XE series are suitable to be mounted on the following bases for plug-in connection:

Generic reference	Designation	Suitable for
R9XEDOM3PNP12	Distri 12M	3P+N circuit-breakers
R9XEDOM3PNP18	Distri 18M	
R9XEDOM3PNP24	Distri 24M	
R9XEDOM3PP18	Distri 18M	3P circuit-breakers
R9XEDOM3PP24	Distri 24M	