


CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS

STR/2580/IMQ

Product	Circuit-breakers for overcurrent protection for household and similar installations
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	SCHNEIDER ELECTRIC HUNGÁRIA VILAMOSSÁGI ZRT. Hock János utca 55 8900 Zalaegerszeg – Hungary
Preliminary visit carried out by	—
Rating and principal characteristics	3P+N – Ue = 400 V – 50-60 Hz – Icn = 3000 A Curve B, C or D – In = 6, 10, 13, 16, 20, 25 or 32 A (see Additional Sheet and page 5 of Test Report No. PB18-0024952-01-00)
Trade mark (if any)	
Model/Type Ref.	Series Resi9 XP (see Additional Sheet and page 9 of Test Report No. PB18-0024952-01-00)
Additional information (if necessary)	—
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
• EN 60898-1:2003 + A1:2004 + A11:2005 + A12:2008 + A13:2012	
as shown in the test reports (reference No.)	PB18-0024952-01-00 and from PB18-0024952-01-01 to PB18-0024952-01-21

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.

Milano, 2018-06-08

Signature of the authorized person _____

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731

Fax.: (+39) 02-50991500

e-mail: info@imq.it

20138 MILANO – Via Quintiliano, 43 – ITALY

**STATEMENT OF TEST RESULTS**

Additional Sheet to STR/2580/IMQ

Description of the circuit-breakers for overcurrent protection series Resi9 XP ($I_{cn} = 3000 \text{ A}$)

Curve	Rated current	Generic reference
B	6 A	R9XPQPN3B06
	10 A	R9XPQPN3B10
	13 A	R9XPQPN3B13
	16 A	R9XPQPN3B16
	20 A	R9XPQPN3B20
	25 A	R9XPQPN3B25
	32 A	R9XPQPN3B32
C	6 A	R9XPQPN3C06
	10 A	R9XPQPN3C10
	13 A	R9XPQPN3C13
	16 A	R9XPQPN3C16
	20 A	R9XPQPN3C20
	25 A	R9XPQPN3C25
	32 A	R9XPQPN3C32
D	6 A	R9XPQPN3D06
	10 A	R9XPQPN3D10
	13 A	R9XPQPN3D13
	16 A	R9XPQPN3D16
	20 A	R9XPQPN3D20
	25 A	R9XPQPN3D25
	32 A	R9XPQPN3D32