

CERTIFICATE

Issued to:
Applicant:
Schneider Electric Industries SAS
31 rue Pierre Mendes Eybens
38050 Grenoble Cedex 9, France

Licensee:
Schneider Electric Industries SAS
31 rue Pierre Mendes Eybens
38050 Grenoble Cedex 9, France

Product : 2-pole socket-outlet
Trade name(s) : SCHNEIDER ELECTRIC
Type(s)/model(s) : A9A15310

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2115383


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 2 December 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-116627

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



S. Lehner
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: 2-pole socket-outlet
Trade name(s)	: SCHNEIDER ELECTRIC
Type(s)/model(s)	: A9A15310
Rated current	: 16 A
Rated voltage	: 250 V~
Standard sheet	: III
Method of mounting	: surface-type; special design for DIN-rail
Terminals	: screw terminals
Earthing	: with side earthing-contacts
Shutter	: with shutter
Markings	: are shown on the body

TESTS**Test requirements**

NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 224945900.

Additional information

This certificate replaces certificate No. 2143747.02 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Schneider Electric Belgium SA/NV
Dieweg 3
1180 Brussel, Belgium