

LICENCE

No.: 12055

Issued to:
Applicant:
Schneider MGTE N.V.-S.A.
Dieweg 3
BRUSSEL, Belgium

Licensee:
Schneider MGTE N.V.-S.A.
Dieweg 3
BRUSSEL, Belgium

Product : Low voltage switch disconnectors

Trade name(s) : MERLIN GERIN

Type(s)/model(s) : MULTI 9 Series 150xx

The product and any acceptable variation thereto is specified in the Annex to this licence and the documents therein referred to.

CEBEC Registered Quality hereby declares that the above-mentioned product has been certified on the basis of :


- a type test according to the standard EN 60947-3
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 12

CEBEC Registered Quality hereby grants the right to use the CEBEC certification mark



The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: March 1, 2001


ir. R. Maquestiau,
Managing Director

© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product	:	Low voltage switch disconnectors
trade name(s)	:	MERLIN GERIN
type(s)	:	MULTI 9 Series 150xx
Rated conditional short-circuit current	:	6 kA when protected with fuse-links limiting the cut-off current to maximum 6.42 kA and the Joule integral to a maximum of 74.5 kA ² s, manufactured by Legrand type gL/gG rated current 125 A
Rated operational voltage (U _e)	:	1P/250 V; 2P,3P,4P/415 V
Rated thermal current (I _{th})	:	40 A, 63 A, 100 A and 125 A
Rated frequency	:	50 Hz
Rated insulation voltage (U _i)	:	500 V
Rated impuls voltage (U _{imp})	:	6 kV
Nature of supply	:	AC
Utilisation category	:	AC22A
Method of mounting	:	DIN-RAIL
Degree of protection	:	IP20

Additional information

<i>PRODUCT REFERENCES</i>			
Reference	Current (A)	Voltage (V)	Pattern number
15024	40	250	1
15013	63	250	1
15090	100	250	1
15057	125	250	1
15020	40	415	2
15014	63	415	2
15091	100	415	2
15058	125	415	2
15023	40	415	3
15015	63	415	3
15092	100	415	3
15059	125	415	3
15019	40	415	03
15016	63	415	03
15093	100	415	03
15060	125	415	03

TESTS

Test requirements

NBN-EN 60947-3 : based on EN 60947-3

Test results

The test results are laid down in CEBEC Test File 574258/01.

Remarks

This certificate is based on CCA/B08/2001 and TRF's Nos. 574258.00 up to 574258.04.

Conclusion

The examination proved that all test requirements were met.

Checked by,
project leader

: S.Piras

[Signature] 01/03/2001

Department Manager,
Product Certification

:

[Signature] 01.03.2001.

Certification Manager

:

[Signature] 1/3/2001.

FACTORY-LOCATION(S)

Schneider MGTE N.V.-S.A.
Dieweg 3,
BRUSSEL, Belgium