

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS

STR/2747/IMQ

Product	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	SCHNEIDER ELECTRIC ESPAÑA, S.A. Camino Barranquet, 57 46133 Meliana (Valencia) – Spain
Preliminary visit carried out by	—
Rating and principal characteristics	1P+N; $U_n = 230$ V; Curve B or C; $I_n = 4, 6, 10, 13, 16, 20$ or 25 A type F; $I_{\Delta n} = 30$ mA; $I_{cn} = 6000$ A; $I_{\Delta m} = 4500$ A (see also pages 5 and 7 of Test Report No. PB25-0125171-03)
Trade mark (if any)	
Model/Type Ref.	DPN Vigi series (see also Additional Sheet)
Additional information (if necessary)	—
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)	
• EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016 + A13:2021 • EN 61009-2-1:1994 + A11:1998 • EN 62423:2012 + A11:2021 + A12:2022	
as shown in the test reports (reference No.)	• PB18-0026801-03-00 and from PB18-0026801-03-01 to PB18-0026801-03-14 • PB25-0125171-03

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

The above mentioned standards are in the
CCA scope of the TL as per 2020-10-01

IMQ S.p.A.

Signature of the authorized person _____

Name and function of the authorized person

Milano, 2025-11-25

Fabio Taormina
Business Unit "Product"
"Project Management & Certification" area
"Certification" Sector (voluntary field) – Certification specialist

Via Quintiliano, 43 – 20138 Milano – Italy
Phone: (+39) 0250731
Fax: (+39) 0250991500
e-mail: info@imq.it



STATEMENT OF TEST RESULTS

Additional Sheet to STR/2747/IMQ

Description of the RCBOs DPN Vigi series ($I_{cn} = 6000 \text{ A}$) and related ratings

Curve	Rated current	Colour of the case	Generic reference
B	4 A	Grey	P1B6000B4F30
		White	P1B6000B4F30b
	6 A	Grey	P1B6000B6F30
		White	P1B6000B6F30b
	10 A	Grey	P1B6000B10F30
		White	P1B6000B10F30b
	13 A	Grey	P1B6000B13F30
		White	P1B6000B13F30b
	16 A	Grey	P1B6000B16F30
		White	P1B6000B16F30b
	20 A	Grey	P1B6000B20F30
		White	P1B6000B20F30b
C	4 A	Grey	P1B6000C4F30
		White	P1B6000C4F30b
	6 A	Grey	P1B6000C6F30
		White	P1B6000C6F30b
	10 A	Grey	P1B6000C10F30
		White	P1B6000C10F30b
	13 A	Grey	P1B6000C13F30
		White	P1B6000C13F30b
	16 A	Grey	P1B6000C16F30
		White	P1B6000C16F30b
	20 A	Grey	P1B6000C20F30
		White	P1B6000C20F30b
	25 A	Grey	P1B6000C25F30
		White	P1B6000C25F30b