


# CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC  
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



## STATEMENT OF TEST RESULTS

STR/2590/IMQ

Product	<b>Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)</b>
Tested by request of	<b>SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France</b>
Manufactured at (name and place)	<b>SCHNEIDER ELECTRIC ESPAÑA, S.A. Camino Barranquet, 57 46133 Meliana (Valencia) – Spain</b>
Preliminary visit carried out by	—
Rating and principal characteristics	<b>1P+N – Un = 230 V – Curve B – In = 4, 6, 10, 13, 16, 20 or 25 A type A – IΔn = 30 mA – Icn = 10000 A – IΔm = 4500 A (see also Additional Sheet and pages 4 and 6 of Test Report PB18-0026801-02-00)</b>
Trade mark (if any)	
Model/Type Ref.	<b>Series DPN Vigi (see also Additional Sheet and page 6 of Test Report PB18-0026801-02-00)</b>
Additional information (if necessary)	—
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
<ul style="list-style-type: none"><li>• EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016</li><li>• EN 61009-2-1:1994 + A11:1998</li></ul>	
as shown in the test reports (reference No.)	<b>PB18-0026801-02-00 and from PB18-0026801-02-01 to PB18-0026801-02-07</b>

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

**IMQ S.p.A.**

Milano, 2018-09-24

Signature of the authorized person \_\_\_\_\_

Name and function of the authorized person

**Mauro Casari**

**B.U. "Product Conformity Assessment"  
"Project Management & Certification" Area  
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731

Fax.: (+39) 02-50991500

e-mail: info@imq.it

20138 MILANO – Via Quintiliano, 43 – ITALY

# CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC  
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



## STATEMENT OF TEST RESULTS

Additional Sheet to STR/2590/IMQ

### Description of the RCBOs series DPN Vigi (type A, I<sub>cn</sub> 10000 A)

Rated current	Generic reference
4 A	P1B10000B4A30
6 A	P1B10000B6A30
10 A	P1B10000B10A30
13 A	P1B10000B13A30
16 A	P1B10000B16A30
20 A	P1B10000B20A30
25 A	P1B10000B25A30