

HU-003379

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Moulded-Case Circuit-Breaker Incorporating CBR

Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France

Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France

See additional page(s)

Rated operational voltage (Ue): AC 220-440V Rated insulation voltage (Ui): 500V Rated impulse withstand voltage (Uimp): 8kV Rated current (In): 40A / 100A / 160A / 250A Rated frequency: 50Hz / 60Hz

Schneider Electric

CTF Stage 2

ComPacT NSX 100B, 100F, 100N, 100H, 100S or 100L ComPacT NSX 160B, 160F, 160N, 160H, 160S or 160L ComPacT NSX 250B, 250F, 250N, 250H, 250S or 250L Being equipped with electronic over-current release MicroLogic Vigi 4.2 or 7.2E

3-pole or 4-pole
Overvoltage category: IV
Selectivity category: A
Pollution degree: 3
(See further details in CB Test Report)

IEC 60947-2:2016+A1 See Test Report for National Differences

HU21N81N 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division H-1143 Budapest, Gizella út 51-57., Hungary Web:www.tuv.com



Tamás László Tötös

1 CB 00/2

Date: 2022-07-07

Signature:





HU-003379

Page 2 of 2

- Schneider (Beijing) Low Voltage Co., Ltd No.2, Liang Shui He 2nd Street, Beijing Economic Technological Development Area, 100176 Beijing P.R. China
- 2. Schneider Electric Alpes Voie Isaac Newton ZI Alpespace 73800 Francin France
- 3. Schneider Electric Industries Polska
 Sp. z o.o.
 Ul. Mostowa 19
 32-332 Bukowno
 Poland

Additional information (if necessary)

Report Ref. No. : HU21N81N 001



Date: 2022-07-07 Signature: Tamás László Tötös