


**IH 60mn srm**

Operating instructions



Art. no. CCT15338

**For your safety**

**⚠ DANGER**  
 Risk of serious damage to property and personal injury, e.g. from fire or electric shock, due to incorrect electrical installation.  
 Safe electrical installation can only be ensured if the person in question can prove basic knowledge in the following areas:


- Connection to installation networks
- Connecting several electrical devices
- Laying electric cables

These skills and experience are normally only possessed by skilled professionals who are trained in the field of electrical installation technology. If these minimum requirements are not met or are disregarded in any way, you will be solely liable for any damage to property or personal injury.

**Getting to know the IH 60mn**

The IH 60mn is a mechanical time switch that switches connected loads on or off in the hourly rhythm when the set time has been reached. It is installed on a DIN rail (DIN EN 60715).

**Product details**



- (A) Manual switch
- (B) Setting disc
- (C) Switching segments
- (D) Automatic/permanent switch
- (E) Switch output
- (F) Mains connection


**Installing the IH 60mn**

- ① Place the IH 60mn onto the DIN rail.
  - ② Connect cables:
    - Remove 8 mm (max. 9 mm) of insulation
    - Open the plug-in terminal with a screwdriver and plug in the cable at a 45° angle. (max. 2 cables per plug-in terminal)
- 
- ③ Connect the mains voltage.

**Setting the IH 60mn**

**Setting the switching time**  
 You can set the switching time using the switching segments. Each switching segment represents a 37.5-second time period. The switching segments can be pushed in or out, for example, by using your index finger. The setting disc shows the switching period (< +/- 30 seconds, calculated at 8 switching segments = 5 minutes).

☐ Switching segment out Load switched off  
 ▮ Switching segment in Load switched on



**Example times:**  
 (A) 5 min. on,  
 5 min. off

**Operating the automatic/permanent switch**

With the automatic/permanent switch, you can switch the load permanently on or off or permanently set it to automatic mode.

- Activating permanent ON: Set the switch to "1". The load is switched on permanently. The set switching times are deactivated.
- Activating permanent OFF: Set the switch to "0". The load is switched off permanently. The set switching times are deactivated.
- Activating automatic mode: Set the switch to "clock". The set switching times remain activated. The load is switched on or off when the set switching time has been reached.

**i** For permanent ON or permanent OFF, the set switching times are deactivated.

**Technical data**

Nominal voltage:	AC 230 V (+10% / -15%)
Frequency:	50 Hz
Nominal current:	10 A, cos φ = 1 4 A, cos φ = 0.6
Incandescent lamps:	AC 230 V, max. 1000 W
Halogen lamps:	AC 230 V, max. 1000 W
Fluorescent tubes:	AC 230 V, max. 600 VA
Fluorescent lamps with electronic ballast:	2 x 40 W (12 μF), parallel-compensated
Compact fluorescent lamps with electronic ballast:	25 W
LED lamps:	5 W (LEDs <2 W) 15 W (LEDs 2-8 W)
Power consumption:	0.9 W
Ambient temperature:	-20 °C to +55 °C
Connecting terminals:	2 x 0.5 - max. 2.5 mm <sup>2</sup> , fixed and flexible wires
Accuracy:	Network synchronous
Protection class:	II per EN 60730-1 when installed correctly
Type of protection:	IP 20 in accordance with EN 60529

**Operating the IH 60mn**

**Operating the manual switch**  
 You can switch the load on or off in advance as long as the time switch is on automatic mode .

- ① Turn the manual switch one position anti-clockwise. The current status is reversed and stays unchanged for the next switching.

**Schneider Electric Industries SAS**

If you have technical questions, please contact the Customer Care Center in your country.  
[www.schneider-electric.com](http://www.schneider-electric.com)