



Ref. Certif. No.

DE1-70117

IECEE CBTC

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge protective device

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier
92500 Rueil Malmaison
France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier
92500 Rueil Malmaison
France

Name and address of the factory

Raycap d. o. o. Poslovna cona Zeje pri Komendi
Pod hrasti 7
1218 Komenda
Slovenia*Note: When more than one factory, please report on page 2* Additional Information on page

Ratings and principal characteristics

Class II / III, $U_c = 300 \text{ V L-(PE)N}$; 305 V N-PE , $I_n = 20 \text{ kA L-(PE)N}$; 40 kA N-PE , $I_{max} = 40 \text{ kA L-(PE)N}$; 65 kA N-PE , $U_p \leq 1,5 \text{ kV}$, $U_{oc} = 6 \text{ kV}$, $I_{sccr} = 25 \text{ kA}$

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

A9L2F640, A9L2F140, A9L2F340

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2025-08-27

Signature:

A. Fabian



Ref. Certif. No.

DE1-70117

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Additional Information on page

IEC 61643-11:2011

332469-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2025-08-27

Signature:

A. Fabian