



TYPE APPROVAL CERTIFICATE

Certificate no.:
TAA00002DJ
Revision No:
2

This is to certify:

that the **Miscellaneous Transmitter**

with type designation(s)
Analog Interfaces RMPT, RMT, RMC

issued to

Schneider Electric Asia Pte Ltd
Singapore, Singapore

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Temperature	B
Humidity	B
Vibration	A
EMC	A
Enclosure	*) Required protection according to DNV Rules shall be provided upon installation on board

Issued at **Hamburg** on **2024-05-23**

for **DNV**

This Certificate is valid until **2029-06-26**.

DNV local unit: **Certification of Materials - Singapore**

Approval Engineer: **Torsten Dzillak**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Supply Voltage : 24 V

RMT J/K Converters for J and K type thermocouples
J (Fe-CuNi)
K (Ni-CrNi)

Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA

RMPT . 0 Converters for Universal Pt100 probes
Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA

RMPT . 3 Converters for Optimum Pt100 probes
Output Signal: 0 ...10 V or 0 ... 20 mA

RMC Universal Voltage/Current Converters
Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA
Switchable 0 ... 10 V; +/- 10 V/4 ... 20 mA; 0... 20 mA
0 ...10 V or 0 ... 20 mA or 4 ... 20 mA
Input Signal: 0 ...10 V ; +/- 10 V; 0 ... 50 V; 0 ... 300 V; 0 ... 500 V
4 ... 20 mA; 0... 20 mA ; 0 ... 1.5 A; 0 ... 5 A; 0 ... 15 A

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV Rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Test report : No. 1392463 dated 17-01-2003; No. E39281 dated 14-02-2003; 56S030312/01 dated 07-05-2003 and 55S021675/CTG/TLH dated 08-10-2002; No. 5903 in compliance with Qualification plan index 1661647 00 K1 05 dated from 13-12-2002 to 16-04-2003

renewal audit 2024-04-25

EMC test report 7191331335-EEC24/01 issue 1 dated 29-04-2024 TÜV Süd PSB Singapore
EMC test report 7191326138-EEC24/01 issue 1 dated 16-02-2024 TÜV Süd PSB Singapore

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number

Place of Production:

PT Schneider Electric Manufacturing Batam
Batamindo Industrial Park, Jalan Beringin Lot 4 & 208
Muka Kuning, Batam Island, Indonesia

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE