

**Schneider Electric Buildings AB  
DECLARATION OF PERFORMANCE  
No. DP20033**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

1. Unique identification code of the product-type:  
**FFS06741017 Esmi Impresia Base with Sounder Beacon**
2. Intended use/es:  
**Fire detection and fire alarm systems**
3. Manufacturer:  
**Schneider Electric Buildings AB,  
Mobilvägen 8, 22362 Lund, Sweden**
4. Authorised representative:  
**Not applicable**
5. System/s of AVCP:  
**System 1**
6. Harmonised standard(s):  
**EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006  
EN 54-17:2005, EN 54-17:2005/AC:2007**  
Notified body:  
**EVPU (Notified Body 1293)  
1293-CPR-0892**
7. Declared performance/s:

| Essential characteristics  | Harmonised technical specification                                     |  | Performance |
|--|--|--|-------------|
|  | EN 54-3:2001<br>EN 54-3:2001/A1:2002<br>EN 54-3:2001/A2:2006           | EN 54-17:2005<br>EN 54-17:2005/<br>AC:2007 |             |
| Performance under fire conditions                                | cl. 4.2, 4.3, 5.2, 5.3,<br>C.3.1=N/A, C.3.2=N/A,<br>C.5.1 to C.5.3=N/A | cl. 5.2                                    | Pass        |
| Operational reliability  | cl. 4.4 to 4.6, 5.4,<br>C4=N/A   | cl. 4                                      | Pass        |
| Durability of operational reliability:<br>Temperature resistance | cl. 5.5, 5.6=N/A, 5.7 to<br>5.9  | cl. 5.4, 5.5                               | Pass        |
| Durability of operational reliability:<br>Humidity resistance    | cl. 5.8, 5.9, 5.10=N/A   | cl. 5.6, 5.7                               | Pass        |

|   |                  |                 |      |
|---|------------------|-----------------|------|
| Durability of operational reliability: Shock and vibration resistance | cl. 5.12 to 5.15 | cl. 5.9 to 5.12 | Pass |
| Durability of operational reliability: Corrosion resistance           | cl. 5.11         | cl. 5.8         | Pass |
| Durability of operational reliability: Electrical stability           | cl. 5.16         | cl. 5.3, 5.13   | Pass |
| Durability of operational reliability: Resistance to ingress          | cl. 5.17         | ---             | Pass |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of manufacturer by:

Espoo 2024-03-26

---

Jan Ellonen

Offer Manager

(v2)