

**Schneider Electric Buildings AB
DECLARATION OF PERFORMANCE
No. DP20035**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

1. Unique identification code of the product-type:

FFS06741019 Esmi Impresia Potential Output for Sounder Module

2. Intended use/es:

Fire detection and fire alarm systems

3. Manufacturer:

**Schneider Electric Buildings AB,
Mobilvägen 8, 22362 Lund, Sweden**

4. Authorised representative:

Not applicable

5. System/s of AVCP:

System 1

6. Harmonised standard(s):

EN 54-18:2005, EN 54-18:2005/AC:2007

EN 54-17:2005, EN 54-17:2005/AC:2007

Notified body:

EVPU (Notified Body 1293)

1293-CPR-0888

7. Declared performance/s:

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: Temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: Vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: Humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass

Durability of operational reliability: Corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: Electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of manufacturer by:

Espoo 2024-03-26



Jan Ellonen

Offer Manager

(v2)