

**Schneider Electric Buildings AB
DECLARATION OF PERFORMANCE
No. DP20036**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

1. Unique identification code of the product-type:
FFS06741020 Esmi Impresia Relay Output Module 240V
2. Intended use/es:
Fire detection and fire alarm systems
3. Manufacturer:
**Schneider Electric Buildings AB,
Mobilvägen 8, 22362 Lund, Sweden**
4. Authorised representative:
Not applicable
5. System/s of AVCP:
System 1
6. Harmonised standard(s):
**EN 54-18:2005, EN 54-18:2005/AC:2007
EN 54-17:2005, EN 54-17:2005/AC:2007**
Notified body:
**EVPU (Notified Body 1293)
1293-CPR-0887**
7. Declared performance/s:

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: Temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: Vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: Humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass

Durability of operational reliability: Corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: Electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of manufacturer by:

Espoo 2024-03-26



Jan Ellonen

Offer Manager

(v2)