



5386

SGS

UKCA Type Examination Certificate Number: **0120/SGS0137/R1**

Schneider Electric Pvt. Ltd

Hosur Main Road
12A, Attibele Industrial Area
Neralur (PO), Bangalore -562107
India

Instrument Identification
PM5331, PM5341, PM5111

Polyphase, Active Import/ Export (kWh), Transformer Operated, Electricity Meter

Instrument Traceable Number
0120/SGS0137

has been assessed and certified as meeting the requirements of

Measuring Instruments Regulations 2016 (as amended) on Active electrical energy meters, Schedule 1B, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Schedule 1E, as referenced in the UK Measuring Instruments Regulations 2016, as amended

This certificate must be used in conjunction with a certificate covering the product verification as required in Schedule 1B, Module D or Schedule 1B, Module F

This certificate is valid for 10 years from 17 July 2023 until 17 July 2033
Issue 2

Certification is based on report number(s)
EMA180141/MID Issue 6 Issued 18th November 2014, EMA223584/1 Issued 7th June 2016
EMA225384/1/PM5341 Issued 21st June 2016
ERTL(N)/2020/201Q0101 issued 4th December 2020
ERTL(E)/TES/S724/0016/01-22/NABL issued 13th June 2022
ERTL(E)/TES/S724/0015/01-22/NABL issued 13th June 2022

Authorised Signature

Lewis Lee

Contact Address
SGS United Kingdom Limited, Approved Body 0120
Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com






UKCA Type Examination Certificate Number:

0120/SGS0137/R1


Issue Number: 2

Dated: 04th September 2024**1. Technical Data**

Manufacturer	Schneider Electric
Meter Type	PM5331, PM5341, PM5111
Voltage Rating (U_n)	63.5/110-277/480V
Current Rating (I_{min} – I_{ref} (I_{max}))	0.05-5(6)A
Frequency (F_n)	50Hz
Active Accuracy Class (kWh)	C(kWh)
Type of circuit	3P4W, 3P3W
Temperature Range	-25°C to +70°C
Software/ Firmware Version No's	<p>For HW Ver. A1 (Not in production) Model: PM5111 OS - New: v1.6.5 (Checksum 0x13 E1); Earlier: 1.6.4 / 1.6.2 / 1.6.0 / 1.4.7 / 1.2.2 / 1.2.1 Model: PM5331 OS - New: v1.6.5 (Checksum 0x CB 6B); Earlier: 1.6.4 / 1.6.2 / 1.6.0 / 1.4.7 / 1.2.2 / 1.2.1 Model: PM5341 OS - New: v1.6.5 (Checksum 0x D0 6F); Earlier: 1.6.4 / 1.6.2 / 1.6.0 / 1.4.7 / 1.2.2</p> <p>For HW Ver. B1/B2 (In production) Model: PM5111 OS - New: 2.5.4 (Checksum 0x1B39) Earlier: 2.4.3/2.4.2/2.2.2/2.2.1/2.2.0 Model: PM5331 OS - New: 2.5.4 (Checksum 0xC2EA) Earlier: 2.4.3 / 2.4.2 / 2.2.2 / 2.2.1 / 2.2.0 Model: PM5341 OS - New: 2.7.0 (Checksum 0xEC30), New: 2.6.6 (Checksum 0x1CA6) Earlier: 2.4.4 / 2.4.3 / 2.2.3 / 2.2.1 / 2.2.0</p>
Identification Location	LCD
Bill of Materials No's	<p>PM5111 Power Supply - HRB46840 or NVE50463 Controller – HRB47633 or EAV69955 or NVE50496</p> <p>PM5331 Power Supply - HRB46838 or NVE50412 Controller – HRB44401 or EAV69954 or NVE50494</p> <p>PM5341 Power Supply - HRB46838 or NVE50412 Controller – EAV69953 or NVE50488</p>
IP Rating	IP54 Front Display Meter body not rated, must be fitted in an IP51 Enclosure
Insulation Protective Class	Class II
LED Pulse Constant	10,000imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Tamper evident self-locking rivet
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD

	UKCA Type Examination Certificate Number:	
	0120/SGS0137/R1	
	Issue Number: 2	Dated: 04 th September 2024

Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Associated Documents



2. Photograph of Meter and Sealing Plan




Voltage Terminal
Cover Sealing Point


Current Terminal
Cover Sealing Point



Main Cover
Sealing Point

	UKCA Type Examination Certificate Number:	
	0120/SGS0137/R1	
	Issue Number: 2	Dated: 04 th September 2024

3. Examples of Nameplate




CE M23 ECTEC 0598/SGS0137
 UKCA M23 0120/SGS0137
 50 ME
 ENEC
 C UL US LISTED MEASURING EQUIPMENT
 Made in India Hecho en India 125-250V ± 20% < 4W Accuracy class 0.5S
 100-277V LN/415V LL ± 10%~
 50/60 ± 5 Hz < 11VA
 (8) (9)
 L1 L2
 CONTROL POWER
⚠ DANGER / PELIGRO
 HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH
 RIESGO DE DESCARGA ELÉCTRICA, EXPLOSIÓN O DESTELLO DE ARCO
 RISQUE D'ÉLECTROCUTION, D'EXPLOSION OU D'ARC ELECTRIQUE
 INPUTS/OUTPUTS
 Outputs: 40V = MAX, 20mA = MAX
 Inputs: 24V = MAX, 8mA = MAX
 Whichever
 CURRENT INPUTS
 1A/5A NOM, 0.05-5(6) A
 I₁₊(10) I₁₋(11) I₂₊(12) I₂₋(13) I₃₊(14) I₃₋(15)

MID SPECIFICATIONS

Accuracy Class C -25°C ... 70°C
 10,000 imp/kWh

Input:
 3x63.5/110 ... 3x277/480 V
 0.05-5(6) A, 50Hz





UKCA Type Examination Certificate Number:

0120/SGS0137/R1

Issue Number: 2

Dated: 04th September 2024

4. Calculation of the composite error/ MPE


During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

- $\delta e(T, I, \cos\phi)$ = Additional error due to variation of the temperature at the same load
- $\delta e(U, I, \cos\phi)$ = Additional error due to variation of the voltage at the same load
- $\delta e(f, I, \cos\phi)$ = Additional error due to variation of the frequency at the same load

		Influence Factors For Temperature, Frequency & Voltage						
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
Imin	1.0	0.42	0.28	0.16	0.18	0.26	0.36	0.38
Itr	1.0	0.42	0.27	0.16	0.19	0.28	0.40	0.46
10ltr	1.0	0.32	0.20	0.14	0.19	0.24	0.31	0.32
Imax	1.0	0.31	0.20	0.14	0.19	0.25	0.32	0.49
Itr	0.5ind	0.62	0.43	0.29	0.29	0.44	0.68	0.84
10ltr	0.5ind	0.61	0.41	0.27	0.30	0.42	0.60	0.76
Imax	0.5ind	0.60	0.40	0.27	0.30	0.41	0.61	0.76
Itr	0.8cap	0.42	0.22	0.13	0.18	0.24	0.30	0.30
10ltr	0.8cap	0.21	0.13	0.12	0.16	0.19	0.20	0.16
Imax	0.8cap	0.21	0.13	0.12	0.16	0.19	0.20	0.16
Line 1								
Itr	1.0	0.43	0.33	0.17	0.19	0.31	0.37	0.46
10ltr	1.0	0.36	0.24	0.20	0.23	0.28	0.34	0.35
Imax	1.0	0.34	0.21	0.17	0.21	0.23	0.34	0.34
Itr	0.5ind	0.64	0.42	0.36	0.29	0.36	0.59	0.82
10ltr	0.5ind	0.60	0.37	0.30	0.34	0.41	0.56	0.75
Imax	0.5ind	0.62	0.37	0.26	0.28	0.40	0.60	0.72
Line 2								
Itr	1.0	0.46	0.22	0.18	0.18	0.26	0.36	0.46
10ltr	1.0	0.23	0.16	0.13	0.18	0.23	0.27	0.29
Imax	1.0	0.27	0.17	0.14	0.19	0.25	0.31	0.29
Itr	0.5ind	0.63	0.34	0.23	0.33	0.40	0.71	0.78
10ltr	0.5ind	0.56	0.37	0.22	0.24	0.37	0.54	0.68
Imax	0.5ind	0.57	0.35	0.23	0.25	0.31	0.55	0.72
Line 3								
Itr	1.0	0.35	0.22	0.13	0.23	0.25	0.44	0.52
10ltr	1.0	0.41	0.24	0.17	0.21	0.30	0.37	0.38
Imax	1.0	0.38	0.23	0.14	0.20	0.26	0.32	0.36
Itr	0.5ind	0.66	0.48	0.26	0.33	0.53	0.81	1.09
10ltr	0.5ind	0.73	0.47	0.37	0.39	0.53	0.76	0.86
Imax	0.5ind	0.70	0.36	0.30	0.32	0.39	0.69	0.87


	UKCA Type Examination Certificate Number:	
	0120/SGS0137/R1	
	Issue Number: 2	Dated: 04 th September 2024

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
Model - Description	
PM5111 -	Polyphase, Active Import/ Export (kWh), Transformer Operated, RS485 with 1 Digital Output
PM5331 -	Polyphase, Active Import/ Export (kWh), Transformer Operated, RS485 with 2 Digital Outputs, 2 Digital Inputs, 2 Electromechanical Relays
PM5341 -	Polyphase, Active Import/ Export (kWh), Transformer Operated, RS485 with 2 Digital Outputs, 2 Digital Inputs, 2 Electromechanical Relays, Ethernet

Modifications to the meter(s) described according to approval No. **0120/SGS0137** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

	UKCA Type Examination Certificate Number:	
	0120/SGS0137/R1	
	Issue Number: 2	Dated: 04 th September 2024

6. Document Revision History

Issue	Date	Comments
1	17/07/2023	Initial Issue
2	04/09/2024	New software versions and CRCs PM5111 2.5.4 0x1B39 PM5331 2.5.4 0xC2EA PM5341 2.6.6 0x1CA6 PM5341 2.7.0 0xEC30

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <https://www.sgs.com/en/terms-and-conditions/general-conditions-for-certification-services-english>

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 28 days only.*

END OF CERTIFICATE