

CERTIFICATE FI/41307

Our Ref. HEL-CERT20200199-01



Product Junction box

Type 100891/100892, PHA2562202/PHA2562302, PHA2562602/PHA2562702

Trademark 

Certificate Holder Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500, Rueil-Malmaison, France

Technical information 400 V~, IP21

Other information Surface mounted skirting boxes of white or white/grey insulation material for mounting of apparatus. Snap-on mounting of front cover to rear part.
Temperature range: -15°C to +60°C.

100891/100892: 100891 (rear part), 100892 (front cover)
PHA2562202/PHA2562302: PHA2562202 (rear part), PHA2562302 (front cover)
PHA2562602/PHA2562702: PHA2562602 (rear part), PHA2562702 (front cover)

The product is certified according to the following standard(s) EN IEC 60670-1:2021 + A11:2021


Validity This certificate is valid until 2027-02-08 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2022-02-08

SGS Fimko Ltd

Signature


Joonas Leinonen
Certification Manager



Manufacturer Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500, Rueil-Malmaison, France

Manufacturing site Elda-Eltra Elektrotehnika S.A
Bugno 1, 78-400, Szczecinek, Poland

Directive information The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Additional information The products have certificate SE-S-2200121 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.
This certificate replaces previous certificate FI 30635, dated 2018-11-13, due to renewal of the certificate.

As shown in the Test Report(s) No(s): 2109121STO-001