



Ref. Certif. No.

FR_710996/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Wireless energy sensor
Acti9 PowerTag

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL MALMAISON - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Range Monoconnect M63 : A9MEM15xx series
References : See annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_710996 dated 25/03/2021. Addition of factory(ies)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016
IEC 61010-2-030:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

173451-769684-A Version : 01
173451-769684-B Version : 01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature: Jérôme REYSSON
Certification Officer

Date: 29/10/2021

ANNEX

Name and address of the factories:

LEXEL FABRIKA SIA

Krustpils 35a
LV-1073 RIGA
LATVIA


SCHNEIDER ELECTRIC FRANCE

Zone Industrielle des Agriers
16021 ANGOULEME
FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 29/10/2021



Signature: Jérôme REYSSON
Certification Officer

ANNEX

References, ratings and main characteristics:

Model (Reference)	Rated Power (VA)	Rated Voltage (V) / Frequency (Hz)	Class	IP
A9MEM1520	1VA	200-240V~, 50/60Hz	--	IP20
A9MEM1521	1VA	200-240V~, 50/60Hz	--	IP20
A9MEM1522	1VA	200-240V~, 50/60Hz	--	IP20
A9MEM1540	2VA	3~ 380-415V 50/60Hz	--	IP20
A9MEM1541	2VA	3N~ 220-240/380-415V 50/60Hz	--	IP20
A9MEM1542	2VA	3N~ 220-240/380-415V 50/60Hz	--	IP20
A9MEM1543	2VA	3~ 200-240V 50/60Hz	--	IP20



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 29/10/2021

Signature:



Certification Officer