

IEC**IECEE**

Ref. Certif. No.

FR_712540/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL-MALMAISON
FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL-MALMAISON
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

ComPacT NSX400 NA,
ComPacT NSX630 NA

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_712540 dated 29/10/2021. Change name of one factory, modify a product picture

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020
IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2111990016, 2111990016A1

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature:
Julien GAUTHIER
Certification Officer

Date: 18/07/2022

ANNEX

Name and address of the factories:

SCHNEIDER (BEIJING) LOW VOLTAGE Co., Ltd
 No 2, Liang Shui He 2nd Street, Beijing Economic Technological Development area
 100176 BEIJING – CHINA

Schneider Electric India Pvt Ltd
 SURVEY NO 215, GAGILLAPUR VILLAGE, MEDAK ROAD, RANGAREDDY DISTRICT
 500 043 HYDERABAD (A.P.) - INDIA

SCHNEIDER ELECTRIC Alpes
 Voie Isaac Newton ZI Alpespace
 73800 Francin - FRANCE

SCHNEIDER ELECTRIC INDUSTRIES POLSKA Sp z.o.o.
 ul. MOSTOWA 19
 32-332 BUKOWNO - POLAND

References, ratings and main characteristics:

Model	Rated current I_e (A)	Model	Rated current I_e (A)
NSX630 NA	630A	NSX400 NA	400A

Technical Characteristics

Utilization category	AC-22A, AC-23A
Method of operation	Independent manual operation
Suitability for isolation	Suitable
Protection degree :	IP40 for front cover
Number of poles :	3P, 4P
Kind of current :	AC
Rated operational voltage U_e : (V)	AC690V
Rated insulation voltage U_i : (V)	800V
Rated impulse withstand voltage U_{imp} : (V)	8kV
Conventional free air thermal current I_{th} : (A)	Same as I_e
Rated operational current I_e : (A)	See above table
Rated uninterrupted current I_u : (A)	Same as I_e
Rated short-time withstand current : I_{cw} (kA)	5kA/1s for NSX400 NA; 7,6kA/1s for NSX630 NA
Rated short-circuit making capacity : I_{cm} (kA)	7,1kA for NSX400 NA; 8,5kA for NSX630 NA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 18/07/2022



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer